



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/GH/2022/SZ/ 867

Dated: 10/10/2022

To

The Addl. Commissioner of Police (Lic/Branch),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Hotel Galaxy, situated at A-184, Gali No- 1, Mahipalpur, N.H-8, New Delhi-110037

Sir,

This has reference to with **MHA Portal ID 2021092122046 dated 07/09/2022** on the subject above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 21/09/2022 in the presence of Mr. Rohit Kumar to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. The occupancy at 4th floor not acceptable as per clause 7.31 of UBBL 2016.
2. Further, it is requested to comply the fire safety provisions under clause 7.31 of UBBL- 2016 in the building, in compliance with the notification of dated 27/05/2019 and as approved and further extended the deadline/ time limit by the Directorate of Local Bodies, UDD, GNCT of Delhi vide their letter no. F5 (189)/AD/LB/2016/5514-31 dated 31.05.2022 for compliance on or before **30/09/2022**

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to

1. M/s Hotel Galaxy, situated at A-184, Gali No- 1, Mahipalpur, N.H-8, New Delhi-110037