

e-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2022/637

Dated: 10/10/2022

To

School In charge /HOS,
N.P. Middle School,
Babar Road No. 1,
New Delhi.

Sub: Regarding issuance of FSC in r/o N.P. Middle School, Babar Road No. 1, New Delhi.


Sir,

This has reference to your mail id <fo@ndmc.gov.in> dated 05/08/2022, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 30.09.2022 in the presence of Sh. Ajay Kumar Sharma and following shortcomings were observed.

1. Hose reel hose found nonfunctional.
2. Overhead tank of 10,000 liter found empty.
3. Fire Pump of 450 LPM capacity found non functional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings and inform to this department at the earliest for further consideration in the matter.

Yours faithfully,


(S.K.Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.

