

c 52

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 872

Dated:-11.10/2022

To,

The Manager,  
M/S 3BS Houses Guest House,  
F 31, 32, D.B.G Market,  
Karol Bagh, New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S 3BS Houses Guest House, F 31, 32, D.B.G Market, Karol Bagh, New Delhi. (Id no. 2022081816303 dated 18/08/2022).**

Sir,

This has reference to your online ID No. 2022081816303 dated 18/08/2022, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 27.09.22 in presence of **Manager** and following shortcomings were observed:

1. Smoke management & CO detectors are not installed as per gazette notification 27.05.2019.
2. Fire Pump not in auto mode provision.
3. Hose reel found nonfunctional.
4. PA system found nonfunctional.

Further, building Plan of all floors is not submitted by owner/occupier.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,

  
(S. K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to :-**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.