



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6 /DFS/MS/EH/SZ/2022 / 816

Dated: 14/10/2022

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Bengali Sweet Corner located at G-19, South Extension Market, Part-I, New Delhi-49.

Sir,

This has reference to the online application I.D. no. 2022091517627 dated 15.09.2022 on the subject cited above, it is informed that the said restaurant was inspected by Assistant Divisional Officer (M. Road) from this department on 29.09.2022 in the presence of Mr. Rajesh Jain (Manager) and it was observed that the restaurant is running at ground & 1st floor of the building which is comprised of Ground + 3 upper floors. During the inspection the following shortcomings were observed:

1. Staircase width of 1.50 mtrs not provided.
2. First aid hose reel found non functional.
3. Down comer system found non functional.
4. Fire pump found non functional.
5. Overhead tank capacity 10,000 liters provided against the requirement of 20,000 liters.
6. Exit signages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel:-011-23414000

Copy to:-

The Licensee,

M/s Bengali Sweet Corner located at G-19, South Extension Market, Part-I, New Delhi-49.

9/10/2022