



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

70
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2022/ 641

Dated: 14/10/2022

To

The Principal,
Hari Vidhya Bhawan School,
K-II/600, Sangam Vihar, New Delhi-80.


Sub:- Regarding renewal of Fire Safety Certificate in r/o Hari Vidhya Bhawan School located at K-II/600, Sangam Vihar, New Delhi-80.

Sir,

This has reference to your letter no. HVB/22-23/162 dated 20.09.2022 on the subject cited above, it is informed that the said building was visited by Assistant Divisional Officer (M. Road) from this department on 28.09.2022 in the presence of Manager and it was observed that the shortcomings already communicated by this department vide letter no. F6/DFS/MS/School/SZ/2022/234 dated 20.05.2022 (Photocopy enclosed) has not been completely rectified till date.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST, South Block-C, Defence Colony, New Delhi-24.

C 33

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/ 234

Dated: 20/05/2022

To

The Principal,
Hari Vidhya Bhawan School,
K-II/600, Sangam Vihar, New Delhi-80.


Sub:- Regarding renewal of Fire Safety Certificate in respect of **Hari Vidhya Bhawan School located at K-II/600, Sangam Vihar, New Delhi-80.**

Sir,

With reference to letter no. HVB/22-23/10 dated 11.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 04.05.2022 in the presence of Sh. Sushil Dhankad, (Chairman) and it was observed that the school building has complied with all the fire safety requirements under its domain, as per Directorate of Education circular no. F6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011.

However, 6.0 meters road accessibility for a fire engine is not available due encroachment which is a mandatory requirement as per rule. Hence renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2019/SZ/1214 dated 06.06.2019 cannot be considered at this stage.

Yours faithfully,


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST, South Block-C, Defence Colony, New Delhi-24.