



7.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/ 2022/ 640

Dated: 14/10/2022

To,

The Principal,
S.D Public School,
Kirti Nagar,
New Delhi -110015.

Sub: - Inspection report in respect of SD Secondary School Located at Kirti Nagar New Delhi-110015.

Sir,

With reference to your letter outdoor diary no. 5601 dated 13/09/2022 on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 28/09/2022 in the presence of Sh. Shivam Tripathi (Admin.) to see the functioning of the fire safety equipments provided in the building.


During inspection, it has been observed that the said school is comprised of Ground + Two Upper Floor. Was issued FSC vide letter No.F6/DFS/MS/School/WZ/2018/2363 dated 18/10/2018. Fire safety arrangements such as, Fire Extinguishers, First Aid Hose Reels, Internal Hydrant, MOEFA, Terrace pump, Overhead Tank etc. are provided.

However, following shortcomings were observed: -

1. First Aid Hose Reel is provided but not functional.
2. Internal Hydrant is provided but not functional.
3. Terrace fire pump of 450lpm provided but not functional & not on auto mode.
4. Overhead tank capacity of 2500ltr is found empty.

In view of above shortcomings, the application for renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Directorate of Education Old Secretariat Delhi - 110054.

o/c 
11/10/2022