

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/2022/SZ/ 2526

Dated 14 / 10 /2022

To

The Executive Engineer (Bldg) HQ,
South MCD, 9th Floor,
SPM Civic Centre, Minto Road,
New Delhi- 110002

Sub - Regarding issuance of Fire Safety Certificate in r/o New Girls Hostel A Building (50-A) at IIT Campus, Hauz Khas, New Delhi.

Sir,

This has reference to with **Online ID 10107620 dated 03/10/2022** on the subject above. In this connection, it is to inform you that joint inspection of the premise was conducted by the team of officers from Delhi Fire Service on 06/10/2022 in the presence of Mr Sunny Raman JE (B) MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Width of internal road is blocked due to under construction.
2. Hostel & Canteen exit doors width is 1.35 m & 1.80 against the required width of 1.50 mtr & 2 mtr.
3. Sealing of shafts not in conformity.
4. Fire fighting pumps are not on auto mode.
5. Exit signage not provided.
6. Floor level marking required in lift area.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR