

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/EH/NDZ/2022/ 615

Dated: 14.10.2022

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- **2022091417567** in r/o **True Blue Class Room** (A unit of EVS Green Energy Pvt. Ltd.) situated at Plot No. 4, FF, SF, Atlantic Plaza, I.P. Extension Patparganj, Delhi - 110092.

Sir,

This has a reference to online application ID No.- **2022091417567** dated 16.09.2022 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 04.10.2022 in the presence of Mr. Kurwarpal (Waiter) and observed that building comprised of Ground + 03 upper floors but restaurant is running at First floor & Second floor and following shortcomings were observed during inspection :

1. Alternate staircase through adjoining building found blocked with brick wall.

In addition to above the application needs correction in respect of width of staircase, width of door and width of corridor. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate.

Hence the online application is rejected.

Yours faithfully,


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Manager,
True Blue Class Room (A unit of EVS Green Energy Pvt. Ltd.),
Plot No. 4, FF, SF, Atlantic Plaza, I.P. Extension Patparganj, Delhi -110092.