GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELIII FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/School/2022/ 647

Dated: 19/10/2022

115 619

To

The Principal,

Alok Bharti Sec. School,

Khureji Khas, Delhi - 110051.

Sub: Regarding Fire Safety Certificate in r/o Alok Bharti Sec. School, located at Khureji Khas, Delhi - 110051.

Sir.

This has reference to your letter AB/2022/48 dated 19/09/2022 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 10/10/2022 in the presence of Sh. Sudhir Kumar (H.O.S.) and observed that school building comprised of Ground floor only and the following shortcoming was observed:-

1. Fire Extinguisher's provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner /occupier.

Yours faithfully

(S.K.DUA)

ole Alt

Dy. CHIEF FIRE OFFICER DELHI FIRE SERVICE

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 110054.