

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2022/SZ/ 617  
To

Dated: 14/10/2022

The Dy. Health Officer  
Public Health Department, South Zone  
Green Park, New Delhi 110016.

**Sub:** Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s Juggernaut (A unit of Gardens of the Earth Pvt Ltd) at HS-16, Kailash Colony, New Delhi 110048.

Sir,

This is in reference to with MHA Portal ID 2022082216421 dated 22/08/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 29/09/2022 in the presence of Ms. Radhica (Manager) and observed that the shortcoming intimated vide letter of even no. 933 dated 29/12/2020 has yet not been complied. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to

1. M/s Juggernaut (A unit of Gardens of the Earth Pvt Ltd) at HS-16, Kailash Colony, New Delhi 110048.

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/HQ/ 2020/EH/933

Dated 29/12/2020

To

Joint Commissioner of Police / Lic.  
1st floor, Police Station  
Defence Colony, New Delhi.

**Sub: - Regarding issuance of fire safety certificate in r/o M/s Juggernaut (A Unit of Gardens of Earth Pvt. Ltd.), HS-16, Kailash Colony, New Delhi-48.**

Sir,

This has reference to your online request I D. No. 2020030203278 Dated: 11.09.2020 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.11.2020 in the presence of Sh. Anurag Badoni to verify the fire safety measures installed in the building and observed that the building is comprised of ground and 03 upper floors and restaurant at 2<sup>nd</sup> floor only . Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 There are only one staircase with width of 1.00m against the requirement of two staircase with width of 2.00m & 1.50m wide.
- 2 There are two exit door having width of 2.00m & 1.00m provided against the requirement of two exit door having width of 2.00m & 1.50m wide respectively.
- 3 Smoke Detector system not provided
- 4 MOEFA system not provided.
- 5 Main electrical fire pump capacity of 2280lpm & Diesel driven pump capacity 2280lpm and jockey pump capacity of 180lpm not provided. Terrace pump capacity 450lpm with head 40m not provided.
- 6 Underground water storage tank capacity 1.00.000ltr not provided firefighting purposes.
- 7 Terrace tank capacity 5000ltr for firefighting purposes not provided.
- 8 Exit Signage not provided in the building.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules ,DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doi/fire/FIRE/Home/Forms>.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

Copy to :

1. M/s Juggernaut (A Unit of Gardens of Earth Pvt. Ltd.), HS-16, Kailash Colony, New Delhi-48.