

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/SZ/ 623

Dated : 17/10 /2022

To

The Dy. Health Officer, SDMC
Public Health Officer,
Aurobindo Marg, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s LOPERA located at Ground floor M-37, Greater Kailash-II, New Delhi 110068

Sir,

This has reference to your MHA Portal No. 2021101924555 dated 19/10/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 27.09.2022 in the presence of Mr. Anup to verify the fire safety measures installed in the building and observed that restaurant running at ground floor only. During inspection, following points were observed:

1. There are two exit door having width of 1.0 mtr & 1.0 mtr against the required width of 1.50 mtr each respectively.
2. First aid hose reel not provided.
3. The MOEFA system is not provided..
4. Internal hydrant and yard hydrant not provided.
5. Terrace level pumps capacity 450 LPM not provided.
6. Overhead tank capacity 20,000 ltrs not provided.
7. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.