

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2022/SZ/ 620

Dated: 17.10.2022

To

The Dy. Health Officer, South Zone,
Public Health Department, MCD,
Green Park Zone, New Delhi 110016

Sub: Regarding issuance of NOC in r/o **M/s NAO By BERCOS** located at **M-40, First Floor only**, M Block, Market, Greater Kailash II, New Delhi 110019

Sir,

This has reference to your MHA Portal 2022090517099 dated 08/09/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 27.09.2022 in the presence of Mr. Deepak Kumar (Manager) to verify the fire safety measures installed in the building and observed that the restaurant is running at First floor only of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose Reel not provided.
2. The Internal Hydrant not provided.
3. Terrace level Fire Pump capacity of 450 LPM not provided.
4. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

