

C 23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 645

Dated: 18/10/2022

To,

The Principal,
Nigam Co-Ed. School, Keshopur,
New Delhi-110018.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Nigam Co-Ed. School, Keshopur, New Delhi-110018.

Sir,

This has reference to your letter No. 007 dated 26/08/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 30/09/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Mrs. Rita (Principal) was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings.

1. Building requires major civil maintenance & repairs works.
2. Fire Extinguishers ABC/Co2 type provided but not functional.
3. First Aid Hose Reel provided but not functional.
4. Fire pump having 450 LPM provided but not functional
5. Overhead tank capacity 10,000 provided but found empty.
6. Exit signage's not provided.

In view of above, the fire safety certificate cannot be considered at this stage. As per the undertaking given by the principal placed at C-21 the school is not in use and all staff & students are shifted to Prithvi Park and Tilak Vihar School since 25/10/2018.

Yours faithfully

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, S.D.M.C, Civic Centre, Minto Road, New Delhi-110001.