



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आजादी का
अमृत महोत्सव

CB1

No.F6/DFS/MS/School/SZ/2022/ 649

Dated: 19/10/2022

To

The Principal,
Sardar Patel Vidyalaya,
Lodhi Estate, New Delhi-03

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Sardar Patel Vidyalaya located at Lodi Estate, New Delhi-03.**

Sir,

This has reference to letter no. nil dated 14.09.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 28.09.2022 in the presence of Manager and it was observed that the building is comprised of 02 blocks (Main School building block -Ground + 03 upper floors & Canteen block- Ground + 2 upper floors). During the inspection following shortcomings were observed:-

1. First-aid-hose reels not provided.
2. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

DL 13/10

Copy to:-

1. The Dy. Director of Education (South), Govt. of NCT of Delhi, Sector- 2, R.K. Puram, New Delhi-22.