

7  
C-42

  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/WZ/2022/646

Dated: 18/10/2022

To

The Principal,  
Sarvodaya Kanya Vidyalaya,  
No-2 Madipur,  
New Delhi- 110063.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, No- 2, Located at Madipur, New Delhi – 110063.**

Sir,


Please refer to your letter no. SKV No-2/MP/FS/407 dated 12/09/2022 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 07/10/2022 in presence of Dr. Vandana Sharma (HOS) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2022/122 dated 16/03/2022.

The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	Fire Extinguishers are provided but found Empty.	Rectified
2.	First Hose reels are provided but not functional.	Not –Rectified
3.	Terrace fire pump of 450 lpm is provided but not functional.	Not –Rectified
4.	Exit signages are found removed.	Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.

%c  
12/10/2022