

C.12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/ 625
To

Dated 18/10/2022

The Dy. Health Officer, South Delhi,
Public Health Department, MCD,
Aurobindo Marg, Green Park,
New Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o The Fort City Brewing (A Unit of North Side Brewers Pvt Ltd) located at GF, FF & SF, E-17, Hauz Khas Market, New Delhi 110016

Sir,

This has reference to with **MHA Portal ID 2022062113308 dated 21/06/2022** on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.10.2022 in the presence of Mr. Ashish Ranjan to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. Automatic fire detection & alarming system not provided.
2. One Fire fighting electric pump capacity 2280 LPM with 70m head, one standby fire pump of similar capacity & head and one jockey pump of 180 LPM with head not provided.
3. The underground storage tank of 1, 00,000 ltrs capacity for firefighting not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR