



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव C 18

No.F6/DFS/MS/School/SZ/2022/650

Dated: 21/10/22

To

The Principal,
Vijay Bharti Public School,
H-16/1906, Near Old Police Post,
Sangam Vihar, New Delhi-80.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Vijay Bharti Public School located at H-16/1906, Near Old Police Post, Sangam Vihar, New Delhi-80.**

Sir,

This has reference to your letter no. 350/VBPS/22-23 dated 08.07.22 on the subject cited above. it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 11.10.2022 in the presence of Sh. Satendra Singh (Manager) and it was observed that the building is comprised of ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. 10 nos. of fire extinguishers not provided.
2. Hose reel found non functional.
3. Fire pump found non functional.
4. Overhand tank capacity 10,000 ltrs should be provided instead of 1,000 liters.
5. Exit signages found removed.
6. Auto starting of pump must be provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

o/c [Signature]
10/10

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST, South Block-C, Defence Colony, New Delhi-24.