

2-71

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/GH/WZ/2022/ 892

Dated: 18/10/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlep.lic-dl@nic.in

Subject: Regarding Renewal of NOC from fire safety point of view in respect of M/s West Face Services (Guest House) located at 17-A, North Avenue, Punjabi Bagh, New Delhi- 110026.

Sir,

Please refer to your online application no.- 2022022202535 dated 19/09/2022 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 08/10/2022 in the presence of Sh. Rajesh Gullah to check the shortcomings already issued by this department vide letter No. F6/DFS/MS/WZ/GH/2022/300 dated 21/04/2022.

The Status of shortcomings is as under:-


S.N.	Shortcomings	Status
1.	Fire Check doors are not provided.	Not Rectified
2.	First -Aid Hose reels are provided but not functional.	Not Rectified
3.	CO (Carbon Monoxide) detector system not provided.	Not Rectified
4.	MOEFA is provided but not functional.	Rectified
5.	Automatic sprinklers system is provided but not functional.	Rectified
6.	Internal Hydrant is provided but not functional.	Not Rectified
7.	Main Fire Pump of capacity 2280 lpm & standby pump of same capacity are provided but not functional.	Rectified but not on auto mode
8.	Exit signages are found removed at some places.	Not Rectified
9.	In Electrical shaft, Fire doors are found removed.	Rectified

In addition to above following short coming were observed

1. In Basement a huge amount of Combustible Material is found stored.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements as per law.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Owner/Occupier of M/s West Face Services (Guest House) located at 17-A, North Avenue, Punjabi Bagh, New Delhi- 110026.
 2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.
(dhowestzone@gmail.com)
- o/c
12/10/2022