

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2022/SZ/ 2621

Dated: 17/ 10 /2022

The Executive Engineer (Bldg) HQ,
South MCD, 9th Floor,
SPM Civic Centre, Minto Road,
New Delhi- 110002

Sub:- Regarding issuance of Fire Safety Certificate in r/o Boys Hostel-E, Indian Institute of Technology, Hauz Khas, New Delhi 110016.

Sir,

This has reference to Online ID No 10099873 dated 04.10.2022, on the subject above. In this connection, it is to inform you that the officers concerned of this department along with Mr. Surender Singh JE (Bldg) on 11/10/2022 to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. The clear-cut exit door width is 1.35 mtr against the required width of 1.50 mtr.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected under sub rule 4 of Rule 35 of Delhi Fire Service Rules, 2010. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)

DIRECTOR
DELHI FIRE SERVICE