

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

F6/DFS/MS/2022/ 2864

Dated: 21/10/2022

To,

Sh. Vivek Shukla,
The World Trade Tower,
Barakhamba Lane,
Connaught Place, New Delhi.

Sub:- Regarding renewal of FSC in r/o World Trade Tower, Barakhamba Lane, Connaught Place, New Delhi.

Sir,

This has reference to your letter no Nil dated 27/09/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 11/10/2022 in the presence of Sh. Manish Kumar (Chief safety officer) and Mr. H.S. Negi and the following shortcomings were observed:-

1. Detectors to be provided in left out area.
2. Smoke management system in basement found non functional.

Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Sh. H.S Negi, Liasion Officer, Bharat Hotel Limited, Barakhamba Avenue, Connaught Place, New Delhi.