



No. F6 /DFS/MS/GH/SZ/2022/896

Dated: 21/10/2022

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P.S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o **The Blue Moon Guest House located at Plot no. 91, Pocket-2, Jasola, New Delhi-06.**

Sir,

This has reference to the online application I.D. no. Online ID no. 2022091017353 dated 12.09.2022 on the subject cited above, it is informed that the said guest house was inspected by Assistant Divisional Officer (M. Road) from this department on 27.09.2022 in the presence of Mr. Neeraj Kumar, Manager and it was observed that the building is comprised of Basement + Stilt + Ground + 04 upper floors. During the inspection the following shortcomings were observed:

1. Alternate staircase width of 1.27 meter is not connected to upper floor.
2. Hose reel found non functional.
3. Carbon monoxide (CO) detector not provided.
4. Fire pump found not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Licensee,

The Blue Moon Guest House located at Plot no-91, Pocket-2, Jasola, New Delhi-06.