

423
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/ College / 61

Dated: 21/10/2022

To,
The Assistant Engineer (E),
South – West Elect. Maint. Sub-Division – I,
Sector – 10, Dwarka Court, Dwarka,
New Delhi – 110075.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Integrated Institute of Technology, Located at Sector – 09, Dwarka, New Delhi - 110077.

Sir,

Please refer to your letter No. 23(8)/AE (E)/South – West/S.D-I/PWD/22-23/618, dated 19/09/2022 on the subject mentioned above. In this connection it is to inform you that the above said premises was visited by the officer concerned of this department on 11/10/2022 in presence of Sh. Mohit Sharma (HO) to see the compliance of the shortcomings communicated vide this office letter No. F6/DFS/MS/SZ/2020/2340, dated 21/09/2020 & found that the shortcomings are still not fully complied. However renovation/ repairing work in hostel building is under progress and terrace pumps are found removed in hostel block.

You are requested to apply after completion of renovation/ repairing work & comply the shortcomings under intimation with this department for further consideration in the matter.

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage.

Yours faithfully,

(Atul Gang)
(Director)

Delhi Fire Service

Copy to:-

1. The Registrar, Dwarka Campus, Sector – 16C, Dwarka, New Delhi – 110078.
2. The Principal, Integrated Institute of Technology, Sector – 09, Dwarka, New Delhi – 110077.