

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F 6/DFS/MS/EH/SZ/2022/ 629

Dated: 21 / 10 / 2022

To
The Joint Commissioner of Police,
Lic, Unit 1st Floor, Police Station,
Defence Colony, New Delhi 49.

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s Le Cantine** (Unit of Sisters food craft Pvt Ltd) Situated at 301 & 301A, Second Floor, DLF Promenade Mall, -3, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070.

Sir,

This has reference with your **MHA Portal ID 2022091717713** dated **17/09/2022**, on the subject cited above. In this connection it is to inform you that the premise was inspected by the concern nominated authority of this department in presence of Sh. Manoj on 13/10/2022 to ascertain the availability and operability of fire protection and fire safety measures & observed that the restaurant running at 2nd floor of DLF Promenade Mall, -3, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070 & The shortcomings observed are as below:

1. There is one exit in the restaurant having width of 2 mtr against the required width of 2.0 mtr & 1.0 mtr.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

62