

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/School/663

Dated: 27/10/2022

To,

The Principal,
CRPF Public School,
Sector 16 B, Dwarka, New Delhi

Subject: Renewal of Fire Safety Certificate in r/o CRPF Public School Located at Sector 16 B, Dwarka, New Delhi

Sir,

Please refer to Email dated 26-09-2022 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 07/10/2022 in presence of Ms. Meenu Tiwari (Principal).

During course of inspection the following shortcomings were observed:

1. Staircases are found obstructed/locked at terrace level.
2. Door closer of Fire check doors found removed at some places.
3. Smoke exhaust system in basement found nonfunctional.
4. Terrace pumps found nonfunctional in auto mode.
5. Communication system in lift car found nonfunctional.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054.