

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2022/ 2694

Dated: 27/10/2022

To

The Authorized Signatory,
NCDC Cell, Plot no. 22,
Sham Nath Marg, Civil Lines, Delhi- 54.
email id- ncdccell001@gmail.com

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Guest House G-Block, NCDC at 22, Sham Nath Marg, New Delhi.**

Sir,

This has reference to email dated 22.09.2022 on the subject cited above. It is informed that the guest house was inspected by the officer concerned of this department on 06.10.2022 in the presence of AGM (Engg.) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm not provided which are required as per Gazette Notification dated 27.05.2019.
2. MOEFA not provided.
3. Public address system not provided.
4. Exhaust fans for smoke management not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service
Tel: 011-23412222

Copy to:-

Addl. General Manager (Engg.),
NCDC, 22, Sham Nath Marg, Delhi- 54.