

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS//2022/ 2674

Dated : 25.10./2022

To,

The Executive Engineer (Elect.)
Central Vista project Electrical,
Division -1, CPWD, IP Bhawan,
New Delhi.

Sub:- Inspection of New Parliament Building under Construction for obtaining Fire NOC.

Sir,

This has reference to your letter no. 23(1) /works /CVPED/2022-23/358 dated 12.10.2022 on the subject cited above. In this connection it is to inform that the site was visited by the officers concerned of this department on 13/10/2022 in the presence of Sh. Amit Marvah MEP Head, Sh. Vishesh & Sh. Nilesh Tiwari and site engineers (contractor side) and observed that work is in progress. However, following directions/shortcomings observed during the inspection have been given at the site to the engineers concerned.

1. Installation of fire hydrants/ detection/sprinklers system and compartmentation in service tunnel shall be ensured properly.
2. The width of FCD on the staircases shall not be less than the width of staircase.
3. 04 staircases serving to terrace as proposed in the guidelines shall be provided.
4. Further, it has also been directed / instructed that complete fire safety guidelines issued by this department vide letter no. F6/DFS/MS/BP/2020/440 dated 18.11.2020 shall be complied in letter and spirit.

Yours faithfully



(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:

1. The Chief Engineer (E), PEWZ, Parliament Library, New Delhi. : For information pl.
2. The Superintendent Engineer (E), CVPEC, IP, Bhawan , New Delhi.