



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

C19

No.F6/DFS/MS/School/SZ/2022/667

Dated: 01/11/22

To

The Principal,  
Babu Khem Chand Advocate Memorial Public School,  
Street no. 56, 60ft Road, Subzi Mandi,  
Molarband Extension, Badarpur, New Delhi-44.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of **Babu Khem Chand Advocate Memorial Public School located at Street no. 56, 60ft Road, Subzi Mandi Molarband Extension, Badarpur, New Delhi-44.**

Sir,

This has reference to your letter no. nil dated 24.08.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.10.2022 in the presence of Sh. Himanshu and it was observed that the school building is comprised of Basement (Sealed) + Ground + 2 upper floors. During the inspection following shortcomings was observed:-

1. Hose reel found non functional.
2. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.