

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/DFS/MS/2022/EH/ 635
To

Dated 26/10/2022

Ministry of Home Affair
Portal.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Barbeque Nation (A Unit of Ms Barbeque Nation Hospitality Ltd.) located at 2nd & 3rd Floors, B-2, Gujrawala Town, Part-1, Delhi-110009.
Sir,

This has reference to your online I.D. No. 2022092918403 dated 30.09.2022 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.10.2022 in the presence of Mr. Bijender (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/ premise is comprised of basement, ground & 03 upper floors but (Restaurant is proposed at 3rd floor & 2nd floor half portion kitchen only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 There are two exit doors having width of 1.60m each provided at third floor against the requirements of 2.00m & 1.50m. The second floor kitchen exit door is also not qualifying the requirement of safe means of escape as this escape route is through the kitchen area and only one exit door having width of 1.60m provided at second floor kitchen area against the requirements of one more exit door having width of 1.50m.
- 2 Fire check door not provided.
- 3 Smoke ventilation system is not provided at third floor.
- 4 Electrical Driven Fire Pump capacity of 2280lpm., Diesel Engine Pump capacity of 2280lpm and Jockey Pump capacity of 180lpm not provided.
- 5 Underground fire water tank capacity of 1,00,000ltr not provided.
- 6 The second floor kitchen is all fire safety arrangements not approachable at site.
- 7 L.P.G cylinder distribution pipe line is installed inside the second floor stairwell, which need to be removed.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doi fire/FIRE/Home/Forms>.

Yours faithfully


(A. K. Singh)
Director

Ph: 011-23414000