



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

C-18

No.F6/DFS/MS/School/SZ/2022/ 666

Dated: 01/11/22

To

The Principal,
J.N. International School,
Jagdamba Colony, Village Aali,
Sarita Vihar, New Delhi-76.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **J.N. International School located at Jagdamba Colony, Village Aali, Sarita Vihar, New Delhi-76.**

Sir,

This has reference to your letter no. JNZMT/25/07/274 dated 17.09.2022 on the subject cited above. it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.10.2022 in the presence of Sh. B.K. Jha (Admin. Officer) and it was observed that the school building is comprised of Basement (Sealed) + Ground + 3 upper floors. During the inspection following shortcomings was observed:-

1. Hose reel found non functional
2. Down comer system found non functional.
3. Fire pump found non functional.
4. Exit sinages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

o/c

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.