

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/669

Dated: 01/11/2022

To,

The Principal
MCD Primary Co – Ed School,
Mahavir Enclave, D Block,
New Delhi - 110045.

Subject: Renewal of Fire Safety Certificate in r/o MCD Primary Co – Ed School, Located at Mahavir Enclave, D Block, New Delhi - 110045. (S. ID.1757164)

Sir,

Please refer to letter No nil dated 13/09/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 10-10-2022 in presence of Ms. Kavita Sharma (Principal) for fire safety point of view.

During the course of inspection the following shortcomings are noticed.

1. Fire extinguishers are found empty.
2. Exit signage's found removed.
3. The pota cabins seen in the premises shall not be used for school activities.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Sunil Chaudhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi - 110054