



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/6
आजादी का
अमृत महोत्सव

No.F6 DFS MS/School/SZ/2022/ 668

Dated: 01/11/22

To

The Principal,
S.S. Public School,
B-545, Sangam Vihar, New Delhi-80.

Subj:- Regarding renewal of Fire Safety Certificate in respect of **S.S. Public School located at B-545, Sangam Vihar, New Delhi-80.**

Sir,

This has reference to your letter no. SSPS/01/2022-23 dated 30.08.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 14.10.2022 in the presence of Sh. Jai Prakash (Owner) and it was observed that the school building is comprised of Ground + 2 upper floors. During the inspection following shortcomings was observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters.
2. Hose reel not provided at 1st floor should be provided.
3. Overhead tank capacity 6000 liters provided against the requirement of 10,000 liters.
4. Fire pump found non functional.
5. Exit sinages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

DL

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.