

C-37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 672

Dated: 01/11/22

To,

The Principal,
Smt. Sarti Devi Public School,
Tajpur Khurd, New Delhi-110071.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Smt. Sarti Devi Public School, Tajpur Khurd, New Delhi-110071.

Sir,

This has reference to your letter No. 1082/22 dated 19/09/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 10/10/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Mr. Praveen sharma (Manager) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. An additional First Aid Hose Reel required in each floor.
2. Fire pump having 450 LPM provided but not functional.
3. Overhead tank capacity of 5,000 provided instead of 10,000 ltr and tank found empty.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully


(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.