



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2022/WZ/School/662

Dated: 27/10/22

To,

The Principal,  
St. Mark's Senior Secondary Public School,  
A-Block, Meera Bagh, New Delhi-110087.

**Subj:- Regarding issuance of Fire Safety Certificate in respect of St. Mark's Senior Secondary Public School Located at A-Block, Meera Bagh, New Delhi-110087.**

Sir,

This has reference to your letter no form 'J' dated 13.07.2022 on the subject cited above. In this connection, it is to inform you that the said school building was re-inspected by the officers concerned of this department on 25.08.2022 in the presence of Sh. Rahul Aggarwal (Director).

During the inspection, it was observed that the building is comprised of Ground + 04 Upper Floors. Fire Safety arrangements such as fire extinguishers, first aid hose reel, & Overhead water storage tank etc found provided. However, the following points have been noticed as shortcomings:-

1. The width of internal road 06 m is not provided.
2. Fire check door is not provided in staircase & lift lobbies.
3. Pressurization system in staircase and lift lobbies is not provided.
4. One additional Staircase having width minimum 1.5 mts as mentioned in sanctioned plan, is not provided.
5. Exit signages are not provided.
6. Apply in form "I" being a case of addition/alteration instead of form 'J'.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(Atul Garg)  
Director

Copy to:-

1. The Executive Engineer (Bldg.), Municipal Corporation of Delhi, 8<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi.