

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2022/SZ/ 671

Dated: 01/11/22

To,

The Principal,
Surya Model School, T-Extn.,
Uttam Nagar, New Delhi-110059.

Sub:-Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Surya Model School, T-Extn., Uttam Nagar, New Delhi-110059.

Sir,

This has reference to your letter no. Nil dated 29/09/2022 on the subject captioned above. In this connection, it is to inform you that the above mentioned building/premises was inspected by the officer concerned of this department on 13/10/2022 in the presence of Sh. Rajesh Gupta to verify the compliance of shortcoming already communicated by this department vide letter no. F6/DFS/MS/School/2019/SZ/2950 dated 20/05/2019 & F6/DFS/MS/School/2022/SZ/144 dated 29/03/2022 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours faithfully



(Sunil Chawdhary)

Dy. Chief Fire Officer



Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

(With a request to take further action as school does not have fire NOC)

C-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/2019/SZ /2950

Dated: 20/5/19

To,

The Principal,
Surya Model School,
T-Extn., Uttam Nagar, New Delhi-110059

Sub: Regarding issuance of Fire Safety Certificate in r/o Surya Model School, T-Extn.,
Uttam Nagar, New Delhi-110059

Sir,

This has reference to your letter no. Nil dated 01.02.2019 on the subject cited above. In this regard it is to inform you that school building was inspected by the officer concerned of this department on 04.04.2019 to see the requisite fire safety measures. Sh. Rajesh Gupta (Chairman) was present at the time of inspection


During the course of inspection it was observed that the premises comprised of Ground floor plus four upper floors and height seems to be more than 15 meters. Hence you are advised to submit two sets of sanctioned building plans/regularised building plans with section/elevation of the building on the scale of 1:100 duly marked with fire and life safety system or building plans must be forwarded by building authority for further necessary action w.r.t. issuance of fire safety certificate.

Yours Faithfully,


(ATUL GARG)
CHIEF FIRE OFFICER

Copy to:-

Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054


15/5/19