

C-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/BNDF/183

Dated:-28/10/2022

To

The Manager
M/S Dream Heritage Banquet,
882 GF, East Park Road, Karol Bagh,
Near Ajmal Khan Park, Karol Bagh,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Dream Heritage Banquet, 882, GF, East Park Road, Karol Bagh, Near Ajmal Khan Park, Karol Bagh, New Delhi.

Sir,

This has reference to online ID No. 2022092818325 dated 28.09.22 on the subject cited above. In this connection, it is to inform you that the site was inspected by the officers concerned of this department on 20/10/2022 in the presence of Sh. Naval Singh (Care Taker) and following shortcomings were observed:-

1. Hose reel not covering entire area, required to be extended to cover left out area.
2. Automatic Detection system not provided in entire area.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

✓

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi