

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

C 4)

No. F6/DFS/MS/GH/NDZ/2022/ 936

Dated: 03/11/22

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Adam Guest House** situated at **3843, Machhali Walan, Khirki Tafazzul Hussain, Jama Masjid, Delhi - 06.**

Sir,

This is in reference to online application I.D. no.2022101118932 dated 11.10.2022 on the subject cited above. It is to inform you that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 21.10.2022 in the presence Mohd. Ajim (Manager). During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm not provided which are required as per Gazette Notification dated 27.05.2019.
2. Fire pump not in auto start mode.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,



(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Tel: 011-23412222

o/c
8/11/22

Copy to:-

The Licensee,

M/s Adam Guest House at 3843, Machhali Walan, Khirki Tafazzul Hussain, Jama Masjid, Delhi.