

C-30



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/WZ/2022/ 676

Dated: 7/11/2022

To,

The Principal,
DAV Public School,
Ashok Vihar, Phase-IV,
New Delhi-110052.

Subj.:- Regarding renewal of Fire Safety Certificate in r/o DAV Public School, Ashok Vihar, Phase-IV, New Delhi-110052.

Sir,


Please refer to your email dated 04.10.2022 on the subject cited above. In this connection, it is to inform you that the said building have been inspected by the officer concerned of this department on 14.10.2022 in the presence of Sh. Rajkumar (Accountant) to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/School/2022/584 dated 21.09.2022.

During the course of inspection, it has been observed that the Management has rectified some of the shortcomings, the status is under:-

S. no.	Shortcomings	Status
1.	First-Aid hose reels & Internal Hydrant at each floor is provided but not functional	Rectified
2.	Terrace fire pump of capacity 450 lpm & 180 lpm is provided but not functional	Rectified
3.	Exit Signage's are found removed at some places	Not rectified
4.	There are 06 teen shaded rooms on the terrace floor it shall be removed	Not rectified

In view of the above shortcomings, Fire safety Certificate cannot be renewal at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to :-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.

H.L. OLC
03/11/22