

C 41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/2022/ 674

Dated: 03/11/22

To

The Principal,
Nigam Pratibha School,
Ludlow Castle, Club Road, Civil Lines, Delhi -06.

Sub: - Regarding issuance of "**Fire Safety Certificate**" from fire safety point of view in r/o
Nigam Pratibha School located at **Ludlow Castle, Club Road, Civil Lines, Delhi-06.**

Sir,

This has reference to your letter no. nil dated 27.07.2022 on the subject cited above. In this connection it is to inform you that officer concerned of this department inspected the school/ premises on 15.09.2022 to verify the fire safety arrangements in accordance with the National Building Code Part-IV-2016/ UBBL-2016. At the time of inspection Mohd. Azam Khan (Principal), was present and it was observed that the school building is comprised of ground plus two upper floors. During inspection, following shortcomings were observed:

1. One additional staircase of 1.5 mtr width is required in the building, upto terrace level.
2. Fire pump not in auto start mode.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service o/c
Tel: 011-23414000
82
02/11

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.