

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2022/School/ 673

Dated: 03/11/22

To,


The Principal,
M. C. Primary School,
R-1, Mangol Puri, Rohini Zone,
Delhi-110083.

Sub: Issuance of Fire Safety Certificate in r/o M. C. Primary R-1, Mangol Puri, Rohini Zone, Delhi-110083.

Sir,

This is in reference to your letter No. nil dated 29.08.2022 received through outdoor diary no. 4885 dated 20.08.2022 on the subject cited above. In this connection submitted the building was visited by officer on dated 14.10.2022 however, it has been observed that the shortcoming already issued by this department letter of even No. 2825 dated 11.12.2014 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 11.12.2014 for further consideration in this matter.

Yours Faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

etc
any

C-9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. FG(DFD)/MS/School/2014/2825

Date: 11 / 12 /2014

To

The Principal,
M C Primary School,
R-I & R-II, Mangolpuri,
Delhi 110083

Sub: - Regarding Fire safety Certificate M C Primary School, R-I & R-II, Mangolpuri, Delhi 110083

Sir,

Please refer to your letter No- nil dated 29/01/2014 on the subject noted above. In this connection, this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with Mrs. Savita Verma (Principal) on 25/11/2014 from fire safety point of view and observed that the following general conditions for fire safety in school as per Director of Education Circular dated 01/03/2011 have not been complied.

- (a) ELCB at electric circuit not provided.
- (b) Electric meter board is below staircase and needs to be either shifted or covered with metallic box.

Keeping in view of the above fire safety certificate cannot be considered at this stage. You are requested to provide the fire safety arrangements as per the Circular of Director of Education, issued vide letter no. F6/Estt/CC/FS/11/3298-3398 dated 01/03/2011.

Yours faithfully



(VIPIN KENTAL)
Dy. Chief Fire Officer
Ph: 011-23846352

etc

Copy to:

1. The Principal, M C Primary School, R-II, Mangolpuri, Delhi 110083
2. The Principal, M C Primary School, R-I, Mangolpuri, Delhi 110083
3. The Dy. Director of Education, North MCD, Rohini Zone, Sector 5 Rohini, Delhi.
4. ✓ The Addl. Director of Education, North MCD, Civic Centre New Delhi.