



C 13



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/NDZ/2022/EH/638

Dated: 31/10/2022

To

Authorized Signatory,
M/s Nazeer Foods, Shop No.-215,
Gali No.-03, Karawal Nagar, Delhi-110094.

Sub.:- Inspection Report in r/o M/s Nazeer Foods, Shop No.-215, Gali No.-03, Karawal Nagar, Delhi-110094.

Sir,

With reference to your MHA portal application No.- 2022093018459 dated 03/10/2022 on the subject noted above. In this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 17.10.2022 in the presence of Sh. Satyam Singh.

During the course of inspection it was observed that the building premises is comprised of Ground & Two Upper Floors Only (But Restaurant is running on Ground Floor Only).

Following shortcomings were observed during the time of inspection:-

1. First Aid Hose Reel is not functional.
2. Internal Hydrant is provided but not functional.
3. A Fire Pump of 450 LPM capacity not provided.
4. Overhead tank capacity of 1,000 ltr is provided against requirement of 20,000 ltr.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. Licensing authority is requested to take necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE.

Copy to :-

1. The Joint commissioner of Police (Lic.), P.S. Defence colony, New Delhi-110024.
2. The Dy. Health Officer, Keshav Chowk, Grand Trunk Rd, near Shyam Lal College, Shahdara, New Delhi, Delhi 110032.