

e 43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2022/EH/642

DATED: 02/11/2022

To,

Mr. Sachin (Manager)
M/s punter house cafe reloaded (A unit of crossroad Pvt. Ltd.)
Shop no 102 - 106, first floor City Centre Mall, Plot no – 5,
Sector – 12, Dwarka New Delhi.

Subject: - Renewal of Fire Safety Certificate in r/o M/s punter house cafe reloaded (A unit of crossroad Pvt. Ltd.) Located at shop no 102 - 106, first floor City Centre Mall, Plot no – 5, Sector – 12, Dwarka New Delhi.

Sir,

Please refer to your Email, dated 03/10/2022 on the subject cited above. In this connection it is to inform you that the above said premises was visited by the officer concerned of this department on 11/10/2022 in the presence of Mr. Sachin (Manager) to see the compliance of the shortcomings communicated vide this office letter No. F.6/DFS/MS/SZ/2022/EH/547, dated 02/09/2022 and found that the shortcomings are still not fully complied. You are requested to comply all the shortcomings under intimation with this department.

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Officer

10/11/22
27/10/22

Copy to:-

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.

036

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/EH/547

DATED: 02/09/2022

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire Safety Certificate in r/o M/s punter house cafe reloaded (A unit of crossroad Pvt. Ltd.) Located at shop no 102 - 106, first floor City Centre Mall, Plot no – 5, Sector – 12, Dwarka New Delhi.

Sir,

This is in reference to MHA application No. 2022072415116, dated 03/08/2022 & 2022081316144 dated 16/08/2022 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officers concerned of this department on 25/08/2022 in the presence of Sh. Sachin (Manager).

During the course of inspection followings shortcoming are observed:-

1. One exit found blocked.
2. Detectors are found nonfunctional.
3. Restaurant activities are noticed in the balcony.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Manager M/s punter house cafe reloaded (A unit of crossroad Pvt. Ltd.), shop no 102 - 106, first floor City Centre Mall, Plot no – 5, Sector – 12, Dwarka New Delhi.