

e68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/GH/929

Dated:-02.11.2022

To

The Manager
M/S Raj Deluxe Guest House,
8467, Arya Nagar, Pahar Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Raj Deluxe Guest House located at 8467, Arya Nagar, Pahar Ganj, New Delhi.

Sir,

This has reference to Online id no. 2022082916788 dated 10/10/22, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on 27/10/2022 in the presence of **Manager** and following shortcomings were observed:-

1. Smoke management system not provided as per gazette notification dated 27.05.2019.
2. Hose reel not provided at each floor.
3. CO detectors are not installed at corridor.
4. Building plan as uploaded on the portal is not signed by architect and owner him self.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.