

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/CGHS/2022/ 2779

Dated 07/11/2022

To,

The President <palmsdwarka@gmail.com>
CBIP CGHS Ltd.
Plot No. 8B, Sector - 07,
Dwarka, Phase - 1, New Delhi - 110075

Subject: Renewal of Fire Safety Certificate in r/o CBIP CGHS Ltd. Located at Plot No. 8B, Sector - 07, Dwarka, Phase - 1, New Delhi - 110075.

Sir,

This is in reference to your Email, dated-08/10/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 25/10/2022 in presence of Sh. Umesh (Manager)


During course of inspection the following shortcomings were observed.

1. Six meter wide internal road around the building found encroached/ blocked.
2. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers
3. Pumps at ground level and terrace level found non functional in auto mode.
4. Exit signage found removed at some places.
5. Communication system in the lift car found removed.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

✓
Copy to; - The Joint Director, DDA, Vikas Sadan, INA, New Delhi.