

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2022/ 944

Dated:- 7.1.1/2022

To,

The Manager,
M/S C.G. International Guest House,
5568-69, Shora Kothi, Pahar Ganj,
New Delhi.

Sub: Regarding renewal of FSC in r/o M/S C.G. International Guest House, 5568-69, Shora Kothi, Pahar Ganj, New Delhi.


Sir,

This has reference to your online ID No. 2022052010776 dated 29.09.2022, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 27.10.22 in presence of **Manager** and following shortcomings were observed:

1. Smoke management is not installed as per gazette notification 27.05.2019.
2. Building plan does not match with profile of the guest house.
Further, undertaking regarding not to use any floor above second floor is required as mezzanine floor is counted as floor.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,


(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.