

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2786

Dated:- 09.11.2022

To,

Sh. Vivek Shrivastav JGM/E& M,
Delhi Metro Rail Corporation Ltd,
Barakhamba Lane, New Delhi.

**Sub: Renewal of FSC (Fire Safety Certificate) in r/o Under Ground Metro Station
Patel Chowk, New Delhi.**

Sir,

This has reference to your e-mail dmrcfirewing@gmail.com dated 20/09/22, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 31.10.2022 in the presence of Sh. Vikas Bhardwaj & Sh. Ravinder and following shortcomings were observed: -

1. Hose reel not covering entire area, required to be extended in left out area.
2. Detectors are not provided in some rooms.
3. Electrical shafts/openings are not sealed horizontally /vertically at some places.
4. Exit signages/ lift signages found inadequate.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,



(S.K.Dua)

Dy. Chief Fire Officer
Delhi Fire Service