

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/ 650

Dated 7/11/2022

To

The Dy. Health Officer, Central Zone,  
Public Health Officer, MCD,  
Jal Vihar, Lajpat Nagar,  
New Delhi 110024.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Dominos Pizza, (Jubilant Foodworks Limited) located at Ground floor, 05, Paras Cinema Nehru Place, New Delhi-110019.


Sir,

This has reference with MHA Portal ID 2022093018456 dated 30/09/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 31.10.2022 in the presence of Mr. Ankur (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at ground floor only. During inspection, following points were observed:

- 1 There are two exit door having width of 1.5 mtr (from front side) & 1.0 mtr (through Kitchen) against the required width of 1.50 mtr each respectively. The rear side exit door/ escape route is through kitchen area which is not acceptable as per the provision contained in UBBL -2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1<sup>st</sup> Floor, P S Defence Colony, New Delhi - 110049. For taking necessary action on the matter.