

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 679

Dated: 9/11/22

To,

The Principal,
New Jagdish Tara Lancers Public School,
C-8,9,10, Maharani Enclave, Hastal Village,
Uttam Nagar, New Delhi 110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o New Jagdish Tara Lancers Public School, C-8,9,10, Maharani Enclave, Hastal Village, Uttam Nagar, New Delhi 110059.

Sir,

This has reference to your letter No. Nil dated 23/09/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 12/10/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Mr. Manish sharma (Manager) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. Second staircase having 1.35 m provided in place of 1.5 m
2. First Aid Hose Reel provided but not functional.
3. Fire pump having 450 LPM provided but not functional.
4. Overhead tank capacity of 5,000 provided instead of 10,000 ltr.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

9/11/22

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.