

C 79

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 680

Dated: 09/11/22

To,
The Principal,
Stanford British School,
Najafgarh Gurgaon Road, Chhawla, New Delhi

Sub: - Regarding issuance of Fire Safety Certificate in r/o Stanford British School, Najafgarh Gurgaon Road, Chhawla, New Delhi

Sir,

This has reference to your letter No. SBS/2022-23/FD/205 dated 19/09/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 12/10/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Priyanka was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. Both the staircases shall be provided 1.5 m wide.
2. Door size having .93 m provided in place of 1 m.
3. First Aid Hose Reels are not provided.
4. Fire pump having 450 LPM not provided.
5. Overhead tank capacity of 10,000 liters not provided.
6. Exits signage's are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi- 110054.