

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/Hospital/2022/ 2806

Dated: 11 / 11 /2022

To,

Sh. Rajender Gupta (Chairmen),
M/s Vinayak Hospital, Derawal Nagar,
Model Town, Delhi-110009.

Sub: - Issuance of Fire Safety Certificate in r/o M/s Vinayak Hospital, Derawal Nagar, Model Town, Delhi-110009.

Sir,

This has reference to your letter received through email dated 06.10.2022 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officers concerned of this department on 19.10.2022 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Harish (Attendant) also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground & 03 upper floors only and the observations/ shortcomings made are as under:-

1. Three nos. of staircase provided in basement having width of 1.20m, 85cm & 75cm against the requirement of 02m & 1.50m.
2. Doors width of ward & ICU are 90cm & 1.70m against the required width of 1.25m & 02m.
3. Pressurization system is not provided in lift shafts & lift lobby's are not provided.
4. Staircase serving to basement is not segregated at ground floor.
5. One room & one kitchen semi permanent vacant on third floor terrace level area which needs to be removed.

Keeping in view of the above Fire Safety Certificate cannot be considered at this stage.

Yours faithfully

(Mural Singh)
Director

Ph:-011-25414000