

620

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 692

Dated: 14/11/2022

To,

The Principal,
D.R.M Public School,
1050, Jain Nagar, Karala Road,
Delhi-110081.

Sub: Issue of FSC in r/o D.R.M Public School, 1050, Jain Nagar, Karala Road, Delhi-81.

Sir,

Kindly reference to online e-mail dated 14.10.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **03.11.2022**, in presence of **Sh. Anshul Mathur (TGT)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. The width of staircase is 1.30 to 1.10 mtr against the required width of 1.5 mtr each.
2. First Aid hose reel not provided.
3. Terrace Fire pump with capacity 450 LPM provided
4. Over Head water captive tank of 10,000 ltrs not provided.
5. Exit signage not provided.

As this is a case of addition/alteration, you are requested to submit sets of building plans on a scale of 1:100 including elevation for entire building through building sanctioning authority i.e MCD/DDA duly marked with fire & life safety provisions as stipulated in NBC.

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel; -01123414250

etc
[Handwritten initials]